

**CITY BUILDING DEPARTMENT INSPECTION REQUIREMENTS:**

1. INSPECTION REQUIRED BEFORE ANY WORK IS STARTED TO DETERMINE CONDITION OF WELL.
2. INSPECTION REQUIRED AFTER 6' EXCAVATION AND CASING IS CUT OFF TO DETERMINE IF WELL CASING IS CLEAR.
3. INSPECTION REQUIRED TO VERIFY FILL LEVEL OF INORGANIC MATERIAL.
4. INSPECTION REQUIRED AFTER WELL HAS BEEN FILLED TO VERIFY 1' CONCRETE CAP, BEFORE 6' EXCAVATION IS FILLED.




**WELL ABANDONMENT REQUIREMENTS**

NOT TO SCALE

**REVISIONS**

5/3/07

ALL WORK SHALL COMPLY WITH APPLICABLE CODES



**NOTES:**